



Luminaire Schedule							
Symbol	Qty	Label	Arrangement	Lum. Lumens	LLF	Lum. Watts	Description
	14	WM4	WALL MOUNT	57320	0.900	544.8	XLCL-FT-LED-HO-CW
	2	WM3	WALL MOUNT	53365	0.900	544.8	XLCL-3-LED-HO-CW
	2	WM3-2	WALL MOUNT	10126	0.900	96.9	XLCS-3-LED-SS-CW

Calculation Summary							
Label	CalcType	Units	Avg	Max	Min	Avg/Min	Max/Min
Paved Areas & Drives	Illuminance	Fc	1.89	19.1	0.0	N.A.	N.A.
Property Line	Illuminance	Fc	0.02	0.3	0.0	N.A.	N.A.

**FOR PRICING REQUESTS
CONTACT RUSS MILLER:
317-780-8350
rmiller@cbmcinc.com**

PHOTOMETRIC NOTES	
MOUNTING HEIGHT	30'
LIGHT LOSS FACTOR	0.90
REFLECTANCES	--
FOOTCANDLES CALCULATED AT	@ GRADE

Based on the information provided, all dimensions and luminaire locations shown represent recommended positions. The engineer and/or architect must determine applicability of the layout to existing or future field conditions. This lighting pattern represents illumination levels calculated from laboratory data taken under controlled conditions in accordance with Illuminating Engineering Society approved methods. Actual performance of any manufacturer's luminaire may vary due to variation in electrical voltage, tolerance in lamps, and other variable field conditions.

STAMP		
NO	REVISIONS DATE	BY

NO	REVISIONS DATE	BY

DRAWN BY: SJM
ISSUE DATE: 12/6/17
DRAWING NUMBER: CB12170-SITE-2