



**GENERAL NOTES:**

- A. REFER TO GENERAL NOTES ON SHEET E001 FOR ADDITIONAL DETAILS AND REQUIREMENTS.
- B. ALL EXTERIOR LIGHTING BRANCH CIRCUITS SHALL BE #10 MINIMUM.

LIGHTING CALCULATION SUMMARY						
AREA	UNITS	AVG	MAX	MIN	AVG/MIN	
PARKING LOT AREAS & DRIVE	FC	4.23	12.7	0.8	5.29	15.88
DRIVE-THRU CANOPY	FC	3.21	7.5	0.7	4.59	10.71
BLDG SITE - WEST, EAST & SOUTH	FC	2.06	5.1	0.1	20.60	51.00

**1 ELECTRICAL SITE LIGHTING CALC POINTS**  
SCALE: 1" = 20'-0"

REVISIONS	DATE	REMARKS



OWNER/CLIENT  
**BCCLT**  
 CONSULTING ENGINEERS  
**KRUSE**  
 CONSULTING ENGINEERS  
 10000 N. STATE ST. SUITE 100  
 INDIANAPOLIS, IN 46260  
 PH: 317.225.5555 FAX: 317.225.5551

CONSULTANTS  
**GUIDON**  
 DESIGN  
 SUSTAINABLE  
 ARCHITECTURE + ENGINEERING  
 3150 N. STATE ST. SUITE 100  
 INDIANAPOLIS, IN 46260  
 PH: 317.225.5555 FAX: 317.225.5551

DESIGN ARCHITECT/ENGINEER

**NOT FOR CONSTRUCTION**

ENGINEER/ARCHITECT'S SEAL

HENDRICKS REGIONAL HEALTH  
 PLANFIELD WEST MOB  
 PLANFIELD, INDIANA  
 SCHEMATIC DESIGN

DESIGNED: Designer	DRAWN: Author
APPROVED: Approver	CHECKED: Checker
CLIENT PROJECT NUMBER	N/A
PROJECT NUMBER	17-1010
DATE	10.25.2018

ELECTRICAL SITE LIGHTING CALC POINTS  
**E003**